



PAVEMENT REMOVAL AND REPLACEMENT PERMIT

PROJECT INFORMATION:

Project Name: _____ Request Date: _____

Project Location/Address: _____

Subdivision Name: _____ Lot: _____ Block: _____

Paving Type: Fire Lane Driveway Barrier Free Ramps

Sidewalk Parking Lot/Drive Isle Dumpster Pad

Material Type: Concrete Replace Asphalt New Asphalt (requires Council approval)

Description of work: _____

PROPERTY OWNER INFORMATION:

Owner Name: _____

Owner Address: _____

Phone No.: _____

Contact Email: _____

PERMITEE/CONTRACTOR INFORMATION:

Company Name: _____

Company Address: _____

Contact Name: _____

Phone No.: _____

Contact Email: _____

ATTACHMENTS (If Applicable)

- Mix Design (required)
 - Site Plan / Area of Construction (required)
 - Typical Sections
 - Traffic Control Plan (required if work to be performed in City or TxDOT ROW. Signed by a licensed professional engineer)
- Other: _____

The City of Rockwall, herein called the City, authorizes _____, herein called the Permittee, to remove and replace the paving listed in this permit.

1. The Permittee agrees to comply with the City's current Standards for Design and Construction.
2. All construction materials shall be subject to inspection by the City's Engineering Construction Inspector listed below.
3. The Permittee shall contact the City's Inspector at least twenty-four (24) hours prior to beginning work on this authorized permit.
4. The Permittee shall hold harmless the City and dully appointed agents and employees against any action for personal injury or property damage sustained by reason of the exercise of this permit.
5. This permit will be null and void if not constructed within six (6) months from the issuance date of this permit.
6. Approved permit must be kept onsite at all times while under construction or inspection.

Replacement Steel Reinforced Concrete Pavement Requirements

Street/Pavement Type	Minimum Thickness (inches)	Strength 28-day (psi)	Minimum Cement (sacks/cy)		Steel Reinforcement	
			Machine Placed	Hand Placed	Bar #	Spacing (O.C.E.W)
Fire Lane	7" *	3,600	6.0	6.5	#3 bars	24"
Driveways	7" *	3,600	6.0	6.5	#3 bars	24"
Barrier Free Ramps	6"	3,600	NA	6.5	#3 bars	24"
Sidewalks	4"	3,000	NA	5.5	#3 bars	24"
Parking Lot/Drive Isles	6" *	3,000	5.0	5.5	#3 bars	24"
Dumpster Pads	7"	3,600	6.0	6.5	#3 bars	24"

*Replacement pavement are shown as 1" thicker than minimum than existing pavement.

Permittee (signature): _____

Date: _____

Permittee (printed): _____

For City Use:

City Engineering Inspector: _____

Inspector Phone Number: _____

Engineering Department: 972-771.7746

City Engineering Authorized Representative

Date of Issuance