PUMPS

FLYGT NP3153, IMPELLER 274 SH 23 HORSEPOWER, THREE (3) PHASE, 460 VOLT.

DESIGN FLOW CALCULATIONS

PHASE I

53 lots X <u>4 people</u> X <u>120 gal/day</u> X <u>1 day</u> X 4 PF = 70.67 gpm ~ 70 gpm 1 lot 1440 min

ULTIMATE

Castle Ridge Estates Build Out

191 lots X <u>4 people</u> X <u>120 gal/day</u> X <u>1 day</u> X 4 PF = 254.67 gpm ~ 250 gpm 1440 min. 1 lot

Offsite Area 29.2 acres ~ 52 Lots

52 lots X <u>4 people</u> X <u>120 gal/day</u> X <u>1 day</u> X 4 PF = 69.3 gpm ~ 70 gpm 1 lot 1440 min

TOTAL FLOW = 320 gpm

WE'T WELL VOLUME STORAGE CALCULATIONS

Per TCEQ, assume 10 starts/hr., 6 min. cycle time.

(Imin)(Qapm) V = 4

For 102,000 gpd (~70 gpm) initial flow For 460,800 gpd (~320 gpm) ulitmate flow

(Imin)(Qapmi

= (6 min * 320 gpm) / 4 = 480 gallons= 64.17 cf

Area of wetwell = $4(7)^2 = 38.5 \text{ sf}$

64.17 cf Required depth = 38.5 sf = 1.67 ft.

Assume/use 2.0 ft. between "On" and "Off"

GENERAL NOTES

THE FOLLOWING ITEMS SHALL BE PROVIDED:

- Fused main disconnect.
- Lightning arrestor.
- Ammeter for each pump.
- Run light for each pump. Seal fail Relays with Pilot Light.
- Main and Generator power transfer switch (Emergency Receptacle (Reversed).
- Control panel, main disconnect and transformer.
- Elapsed time meters for each pump. 110 V receptacle inside control panel.
- All fasteners, anchor bolts etc., Inside wet well and valve vault to be stainless steel.
- 10. Two extra fuses of every size and type used stored at the location where it will be needed.
- 11. Hallogen night lighting on aluminum pole with photo cell. 12. Sign for gate listing

City of Rockwall Castle Ridge Estates

Lift Station

- Emergency #
- 13. Drive and parking shall be 6" thick - 3500 P.S.I. reinforced concrete.
- 14. Aluminum or galvanized control panel frame.
- 15. 8' security black vinyl coated chain link fence with 6' swing gates.

EMERGENCY STORAGE FOR ULTIMATE CONDITION

Per TCEQ, assume 20 minute power outage.

High level alarm = 436.00Wet Well Rim = 448.00

Storage Volume Required for minimum 20 minute power outage. 320 apm * 20 minutes = 6400 ad.

Storage Volume of Wet Well

R = 3.5 ft

H = 12 ft

 $V = \pi R^2 H = 461.8 \text{ cf} = 3454 \text{ gal}$

Storage Volume in Collection System Piping (8" Trunk Lines)

 $V = \pi R^2 L = \pi * 0.33 * L * 7.48 gal/cf = 2.62 gal/ft$ At Elev = 448.0 there is approx. 531 LF of storage in the collection sytstem. V = 531 If * 2.62 gal/ft = 1391 gal

Storage Volume in Manholes

Manhole #1 0+43.54 Flowline = 439.48R = 2 ft

H = 448.00 - 439.48 = 8.52 ft

 $V = \pi R^2 H = 107.1 \text{ cf} = 801 \text{ ad}$

Manhole #2 1+04.15 Flowline = 439.87

R = 2 ft

H = 448.00 - 439.87 = 8.13 ft

 $V = \pi R^2 H = 102.2 \text{ cf} = 764 \text{ gal}$

Manhole #3 3+52.42 Flowline = 444.48 R = 2 ft

H = 448.00 - 444.48 = 3.52 ft

 $V = \pi R^2 H = 44.2 \text{ cf} = 331 \text{ gal}$


TOTAL VOLUME OF STORAGE BELOW EL. 448.00


Wetwell = 3454 gal

Piping = 1391 gal 801+764+331

6741 gal

6741 gal / 320 gpm = 21.0 minutes





NP-3153 PUMP DIMENSIONS NOT TO SCALE

AS BUILT PLANS 05/11/07

The alignment and grade were set on the ground for construction per the plans. The engineer did not verify alignment or grades after construction. We are not aware of any changes or revisions to these plans during construction except as noted.



LIFT STATION DETAIL

CASTLE RIDGE ESTATES PHASE 1

CITY OF ROCKWALL, TEXAS

TIPTON ENGINEERING, INC. ENGINEERING • SURVEYING • PLANNING 6330 Broadway Blvd. • Suite C • Garland, Texas 75043 • (972) 226-2967 DESIGN DRAWN DATE SCALE

4802LS 3-28-06

NOTES "=40' H. TE, Inc. TE, Inc. TE, Inc.