





F.F.E = 559.50

A-1 0.66

A-2 0.62



DRAINAGE TABLE						
NODE ID	AREA (AC.)	С	INTENSITY (IN/HR)	DISCHARGE (CFS)	COMMENTS	
A-1	0.68	0.90	9.8	6.00	INLET#1	
A-2	0.65	0.90	9.8	5.73	INLET#2	
TOTAL	1.33			11.73		

LEGEND					
EXISTING	3	PROPOSED			
	MAJOR DRAINAGE DIVIDE				
/**//*********************************	MINOR DRAINAGE DIVIDE				
Ant	DRAINAGE AREA DESIGNATION A-1				
(0.70)	DRAINAGE AREA IN ACRES 0.70				
	DIRECTIONAL FLOW ARRO	ows 🖚			
	MAJOR CONTOUR @ 5' —	-(555)			
	MINOR CONTOUR @ 1' —	-(555)			
(Control)	GRATE INLET				
Activity training very service of the service of th	STORM SEWER LINE W/CURB INLET				
First Inc.	WATER MAIN, TEE, FIRE HYDRANT & VALVE	<u> </u>			
· · · · · · · · · · · · · · · · · · ·	WASTEWATER MAIN & MANHOLE				
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	ELECTRIC LINE	<u>F</u>			
The state of the s	TELEPHONE LINE	T			
	GAS LINE (BY OTHERS)	G			
	BUILDING LINE	***************************************			
онинувания вонин в на газа на г В верх в в в на газа н	INTEGRAL CURB	<u></u>			
	EASEMENT LINE				
111/14/04/14/04/14/04/14/04/04/04/04/04/04/04/04/04/04/04/04/04	PROPERTY LINE				

BENCHMARKS

B.M. = SQUARE CUT TOP OF CURB CENTER OF CURB INLET N. SIDE OF RALPH HALL PKWY. & 325'± EAST OF MIMS ROAD (45'± W. OF W. PROPERTY LINE) ELEV = 549.34

B.M. = SQUARE CUT TOP OF CURB CENTER OF CURB INLET N. SIDE OF RALPH HALL PKWY. & 1530'± EAST OF MIMS ROAD (65'± W. OF E. PROPERTY LINE)

B.M. = SQUARE CUT ON CONC. BASE OF OVERHEAD SIGN, 16'± N. OF N. EDGE OF I.H. 30 EASTBOUND SERVICE ROAD & 1600'± W. OF MIMS RD. (82'± W. OF E. PROPERTY LINE).

ELEV = 564.23

B.M. = CITY OF ROCKWALL MONUMENT "R07" - BRASS DISK IN CONC., 47'± S. OF CENTERLINE OF I.H. 30 EASTBOUND SERVICE RD. & 105'± E. OF CENTERLINE OF MIMS RD. ELEV = 566.31

RECORD DRAWING

THIS DRAWING HAS BEEN REVISED TO REFLECT
CONSTRUCTION RECORDS MAINTAINED AND PROVIDED BY THE CONTRACTOR FOR THIS PROJECT. DATE: 11-2-05

DRAINAGE T.G.I.

S.A.H. CHECKED

Y.B.

01/15/05 0429